

SUPPLEMENTAL SPECIFICATION

REVISIONS TO SPECIFICATION 710 – FENCE AND GUARDRAIL

The following articles are revised to read as follows:

710-6 CORRUGATED GALVANIZED STEEL BEAM GUARDRAIL

710-6.01 Corrugated galvanized steel beam guardrail and hardware shall conform to the requirements of Class A, type 2, of AASHTO M 180. Requirements to other guardrail appurtenances such as transition, end and buffer sections shall be as specified in the standard drawings.

710-7 GUARDRAIL POSTS

710-7.01 Guardrail posts, plates, and anchoring units shall be fabricated of structural steel conforming to ASTM A36/A36M. These shall be galvanized in accordance with the requirements of AASHTO M111M/M111 (ASTM A 123). Blockouts shall be as specified in the standard drawings.